

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0944:105 Page 1 of 1

NOTE: Ionization Smoke Detectors

LISTEE: Norton, 1902 Airport Rd., Monroe, NC 28110
Contact: *Jeff Trull (704) 283-2101

DESIGN: Models MPD-I and PTD-II. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as ionization smoke detectors for use with separately listed compatible control units. Model MPD-I is intended for use with Model 7200 series door closer/holder (CSFM Listing Nos. 3550-0944:103 and 3550-0944:104). Model PTD-II is intended for use with Models 7700 and 8000 series door closer/holder (CSFM Listing No. 3550-0944:106).

NOTE: 1. Formerly 7256-0944:105
2. 7271-0257:107

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager